# 2018 International Energy Conservation Code (IECC)

Resources
Commissioning
Commercial Mechanical 2018 vs 2009

**Bruce Hauschild** 

bruce.hauschild@nebraska.gov

# Housekeeping

- All participants are muted.
- This event will be recorded and available on <a href="http://dee.ne.gov/">http://dee.ne.gov/</a>
  - Type in "Video Events" (without quotes) in the search bar.
- If you are having audio issues when connecting via computer, please call in via phone at: 1-415-655-0003 access code: 922 849 717
- Certificates will be available for those viewing the presentation live, not for those downloading after the presentation. They will be sent within the next week.

# Questions

- Please feel free to submit questions in chat throughout the presentation. Questions will be answered during specified breaks during the presentation.
- We can stay on longer than the originally scheduled end time to answer questions.
- An FAQ document will be uploaded to the video events page.

## **Contact Information and Questions**

### **Bruce Hauschild**

**Energy Technical Advisor** 

Nebraska Department of Environment and Energy

In addition to submitting questions today via online chat, please feel free at any time in the future to submit question to

bruce.hauschild@nebraska.gov



# 2018 International Energy Conservation Code (IECC)

Resources
Commissioning
Commercial Mechanical 2018 vs 2009

**Bruce Hauschild** 

bruce.hauschild@nebraska.gov

# The Other Code ASHRAE 90.1 2016

Visit <a href="https://www.techstreet.com/ashrae/ashrae\_standards.html">https://www.techstreet.com/ashrae/ashrae\_standards.html</a> or <a href="https://www.ASHRAE.com">www.ASHRAE.com</a> and click on the booksstore

for ASHRAE 90.1 2016

Either ASHRAE 90.1 2016 or the 2018 IECC may be used for energy code compliance in Nebraska, but you must pick one or the other and then that is used for the entire building - envelope, lighting, mechanical, and hot water. a free version of 90.1 is not available.

Careful, ASHRAE 90.1 <u>2019</u> is out Be sure to click on <u>2016</u> if ordering.

## FREE CODES!


Free Online Versions of all Codes from the International Codes Council (ICC) are available.


Visit www.iccsafe.org


At the top of the page click on


**Online Building Codes** 


The 2018 IECC is currently shown In the future you may need to scroll down and "Find Codes by State."













## 2018 IECC® Code and Commentary 2018 International Energy Conservation Code®



FORMAT	PRICE	MEMBER PRICE
premiumACCESS Subscription	\$5.08	\$4.07
1 Month (recurring) ▼		
Free product with purchase of 3 Years option		
Soft Cover Item #: 3810S18	\$76.00 🚯	\$61.00 🚯
Soft Cover & PDF Download Item #: 3810SP18	\$101.00	\$81.00
PDF Download Item #: 878P18	\$68.50 🚯	\$54.50 🐧

FORMAT	PRICE	MEMBER PRI
premiumACCESS Subscription	\$3.42	\$2.50
1 Month (recurring •		
Free product with purchase		
of 3 Years option		
Soft Cover	\$51.50 👩	\$38.75
Item #: 3800S18		
Soft Cover &	\$68.00	\$51.00
PDF/Redline Download		
Item #: 3800SPR18		
PDF/Redline Download	\$46.00 🚯	\$34.50 🚯




June 3, 2020 13


Item #: 8780PR18

## Use COMcheck

Visit <u>www.energycodes.gov</u>
Click on the COMcheck icon
COMcheck is a free energy code compliance software, provided by the
United States Department of Energy



Check compliance with the 2018 IECC, and also ASHRAE 90.1



COMcheck reports provide a comprehensive checklist.

Easy for the Designer to check compliance

Easy for the Code Official to check compliance

## COMcheck has support not only for software questions, but also for code questions.



COMcheck-Web simplifies commercial and high-rise residential energy code compliance. It performs just like the desktop version of COMcheck. but you don't need to download or install any software on your computer.

#### COMcheck Support

Have a compliance question or need assistance with the software?

BECP's team of building energy codes experts is available to answer specific questions submitted through our web-based help desk 🔒 .

#### Comcheck Software Support Documents

Technical Support Document for Version 3.9.1 of the COMcheck Software

#### Subscribe to updates

To receive updates about compliance tools subscribe to the BECP Mailing List

#### Updates to REScheck and COMcheck Building Energy Code Compliance Software

The U.S. Department of Energy (DOE) is directed to provide technical assistance to states to support the implementation of model residential and commercial building energy codes (42 USC 6833). As part of this assistance, the DOE Building Energy Codes Program provides ongoing support for REScheck and COMcheck compliance software, which are updated based on new editions of the model codes. DOE has published quidance 📆 surrounding its support for the software, including technical assistance requests for modified versions.



### **Building Energy Codes Program**

HOME

**EVENTS** 

ABOUT

DOE » EERE » BTO »BECP » Resource Center

DEVELOPMENT

ADOPTION

COMPLIANCE

RESOURCE CENTER

FAQs

Training

PUBLICATIONS

RESOURCE GUIDES

GLOSSARY

RELATED LINKS

#### **Training**

The Building Energy Codes Program (BECP) offers a variety of training resources related to a variety of special topics and tutorials. A list of the most commonly requested materials is available in the full <a href="Irraining Catalog">Irraining Catalog</a> <a href="Irraining Catalog">B</a>.

#### Energy Codes Commentator webinar-based training series

- What You Need to Know about the New Energy Standard for Commercial Buildings:
- Energy Code Evolution An Overview for Architects
- Troubleshooting REScheck and COMcheck Projects
- Basic HVAC Controls and Energy Codes
- What You Need to Know about the 2018 IECC
- Energy Code Compliance for Metal Buildings
- Buried Ducts: Advantages, Challenges, and New Options in the 2018 IECC

www.energycodes.gov free training most provide CEU's

# Resources Any Questions?

Please be reminded, in addition to submitting questions today via online chat, please feel free at any time in the future to submit question to

bruce.hauschild@nebraska.gov

## Commissioning, Section C408

**Exceptions:** The following systems are exempt:

Mechanical systems and service water heater systems in buildings where the total mechanical equipment <u>capacity</u> is less than 480,000 Btu/h (40 tons or 140.7 kW) cooling capacity <u>and</u> 600,000 Btu/h (50 tons or 175.8 kW) combined service water-heating <u>and</u> space-heating <u>capacity</u>. (check your sizing) "or"

Systems included in Section C403.5 that serve individual dwelling units and sleeping units. (thought to be an error as C403.5 is about economizers?-have contacted IECC, no word at this time)



## Commissioning, Section C408

### Building operations and maintenance information.

The building operations and maintenance documents shall be provided to the owner and shall consist of:

- Manufacturers' information, specifications and recommendations;
- 2. Programming procedures and data points;
- Narratives; and
- 4. Other means of illustrating to the owner how the building, equipment and systems are intended to be installed, maintained and operated.



## Commissioning, Section C408

Mechanical systems and service water-heating systems commissioning and completion requirements.

Prior to the final mechanical and plumbing inspections, the registered design professional or approved agency shall provide evidence of mechanical systems commissioning and completion in accordance with the provisions of this section.

### Label the Equipment.

Required regular maintenance actions for equipment and systems shall be clearly stated on a readily visible label. The label shall include the title of publication number for the operations and maintenance manual for that particular model and type of product.



## Commissioning, How are you affected?

### Registered Design Professional or Approved Agency.

Have you met, or are you aware of who the commissioning agent will be? The commissioning agent <u>does NOT have to be a third party</u>, but will be either, by code definition, a "registered design professional," or an "approved

agency" which is an agency approved as acceptable by the code official.

**OEM Manuals.** How many will the commissioning agent need?

**Time.** Have I included time on my bid for commissioning, how much?

**Balancing.** Are you currently ensuring systems are balanced?

**Performance tests.** Are you currently testing equipment performance?

Controls. Will you be required to ensure controls are properly set?

**Economizers.** Are economizers set and tested for functionality?



# Commissioning Any Questions?

Please be reminded, in addition to submitting questions today via online chat, please feel free at any time in the future to submit question to

bruce.hauschild@nebraska.gov

**Load Calculations.** Same as 2009, ANSI/ASHRAE/ACCA Standard 183 Peak Cooling and Heating Load Calculations in Buildings <u>Except Low-Rise Residential</u> Buildings – Trane Trace\*, HAP\*, <u>and other</u> software. (\*not a recommendation)

Remember the Commissioning Exemptions! How about Economizer exemptions?

They are Based on Capacity.


**Equipment Sizing.** The output capacity of heating and cooling equipment shall be not greater than that of the smallest available equipment size that exceeds the loads calculated.

**Zone Isolation.** HVAC Systems serving zones that are over 25,000 square feet in floor area or that span more than one floor and are designed to operate or be occupied *nonsimultaneously* shall be divided into isolation areas. Each isolation area shall be equipped with isolation devices and controls configured to automatically shut off the supply of conditioned air and outdoor air to and exhaust air from the isolation area. Isolation devices include separate systems, isolation dampers and controls providing shutoff at terminal boxes.



Hot gas bypass limitation. Limited to 50% of total capacity for systems with a rated capacity of less than or equal to 240,000 Btu/h, and 25% of total capacity for larger systems.






#### **Boiler Turndown.**

1 million to 5 million Btu/h must have a minimum 3 to 1 turndown 5 million to 10 million Btu/h must have a minimum 4 to 1 turndown Over 10 million Btu/h must have a minimum 5 to 1 turndown Can be met with multiple single input, modulating, or combination. Controls must lower boiler water temperature based on outdoor temperature.

Vestibule and air curtain heating and cooling. Separate controls. shut the heating system down when the outdoor temp is greater than 45°F. Can't heat over 60°F or cool below 85°.

**Setback Controls.** Now mandatory with a detailed description of automatic setback and start configurations.



### Hydronic System Part Load Control. Must meet three control conditions:

- 1. Automatically reset the supply water temp... some wording changes here
- 2. Automatically vary fluid flow on combined pump HP of 2 HP or more...
- 3. Automatically vary pump flow on heating water systems, possibly requiring vfd's. When vfd required, power input shall not be more than 30% wattage at 50% flow. (there are four exceptions to this 403.4.4 paragraph 4.)

# Mechanical (First ½) Any Questions?

Please be reminded, in addition to submitting questions today via online chat, please feel free at any time in the future to submit question to

bruce.hauschild@nebraska.gov

## Mechanical, – Economizer Exceptions

## **Economizer Exceptions.**

- 1. Where more than 25 percent of the air designed to be supplied by the system is to spaces that are designed to be humidified above 35°F dewpoint temperature to satisfy process needs.
- 2. Systems expected to operate less than 20 hours per week.
- 3. Systems serving supermarket areas with open refrigerated casework.
- 4. Systems that include a heat recovery system in accordance with Section C403.9.5 (Heat recovery for service water heating see later slide)



## Mechanical, - Economizers

**Economizers.** An air or water economizer shall be provided for:

1. Chilled water systems with a total cooling capacity, less cooling capacity provided with air economizer, of 1,320,000 Btu/h (110 ton) for Local Water-cooled Chilled-water Systems, or 1,720,000 (143.3 ton) for Air-cooled Chilled-water Systems or District Chilled-Water Systems.



2. Individual fan systems with cooling capacity greater than or equal to 54,000 Btu/h (4.5 ton) in buildings having other than a Group R occupancy. The total supply capacity of all fan cooling units not provided with economizers shall not exceed 20 percent of the total supply capacity of all fan cooling units in the building or 300,000 Btu/h (25 ton), whichever is greater. (300,000 Btu/h up to 1,500,000 Btu/h)

## Mechanical, – Economizers

**Economizers.** An air or water economizer shall be provided for:

3. Individual fan systems with cooling capacity greater than or equal to 270,000 Btu/h (22.5 tons) in buildings having a Group R occupancy. The total supply capacity of all fan cooling units not provided with economizers shall not exceed 20 percent of the total supply capacity of all fan cooling units to the building or 1,500,000 Btu/h (125 tons), which ever is greater. (You're exempted up to 125 tons)



**C403.9.5 Heat recovery for service water heating.** Condenser heat recovery shall be installed for heating or reheating of service hot water provided that the facility operates 24 hours a day, the total installed heat capacity of water-cooled systems exceeds 6,000,000 Btu/h of heat rejection, and the design service water heating load exceeds 1,000,000 Btu/h... and more)

## Mechanical, the rest of the new code...

After the Economizer section of the 2018 code, the 2009 code has been covered. The 2018 code has an additional 14 pages which cover:

- 1. Integrated economizer control.
- 2. Economizer heating system impact
- 3. Air economizers. Where economizers are required, air economizer systems shall be configured to modulate outdoor air and return air dampers to provide up to 100 percent of the design supply air quantity as outdoor air for cooling.
- 4. Water-side economizers. Where economizers are required, water-side economizers systems shall be configured to cool supply air by indirect evaporation and providing up to 100 percent of the expected system cooling load at outdoor air tempertures of not greater than 55°F dry bulb/45°F wet bulb.

## Mechanical, the rest of the new code...

- 5. Economizer fault detection and diagnostics
- 6. Requirements for mechanical systems serving multiple zones.
- 7. Ventilation and exhaust Systems
- 8. Fans and fan controls
- 9. Heat rejection equipment
- 10. Refrigeration equipment performance
- 11. Construction of HVAC system elements (ducts, pipes, & insulation)
- 12. Mechanical systems located outside of the building thermal envelope.
- 13. Service hot water similar in length to the 2009 IECC, a couple pages, but with some changes.

## Section C406, Additional efficiency! WHERE?

Buildings shall comply with one or more of the following:

- 1. More efficient HVAC performance
- 3. Enhanced lighting controls
- **5. Certain Outdoor Air Systems**
- 7. Enhanced envelope performance

- 2. Reduced lighting power
- 4. On-site renewable energy
- 6. High efficiency service hot water
- 8. Reduced air infiltration

"The ventilation system shall be capable of total energy recovery." C406.6 (#5)

# Mechanical Any Questions?

Search Video Events for Webinar Recording and Materials at <a href="http://dee.ne.gov/">http://dee.ne.gov/</a>

Please be reminded, in addition to submitting questions today via online chat, please feel free at any time in the future to submit question to

bruce.hauschild@nebraska.gov

## Resource Reminder

Visit <a href="www.iccsafe.org">www.iccsafe.org</a>
Click on Online Building Codes for the 2018 IECC and other ICC codes – free viewing

Visit <u>www.energycodes.gov</u> for <u>COMcheck</u> – free compliance software

For ASHRAE 90.1 (2016) www.ASHRAE.com, or

https://www.techstreet.com/ashrae/ashrae\_standards.html - not free

At any time during the year, please feel free to send code questions to

bruce.hauschild@nebraska.gov,

or <a href="mailto:lynn.chamberlin@Nebraska.gov">lynn.chamberlin@Nebraska.gov</a>